

HU-005601

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME **CB TEST CERTIFICATE** Product Moulded Case Circuit Breaker Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Name and address of the applicant Zhejiang, P.R. China Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Name and address of the manufacturer Zhejiang, P.R. China Zhejiang Tengen Electric Co., Ltd. (Yueqing Economic Name and address of the factory Development Zone Branch) No.288 Central Avenue Development Note: When more than one factory, please report on page 2 Zone, Yueqing City, 325604 Zhejiang, P.R. China Ue: AC380V/400V/415V, 500V/550V, 660V/690V; 50/60Hz; Uimp:12kV; Ui:1250V; Rated duty: Uninterrupted duty; In: 500A/630A/700A/800A; Selectivity category: A; Ratings and principal characteristics Pollution degree:3; Ith:800A; 3P/3N(3P+N)/4P; Electromagnetic Compatibility: Environment A (for further ratings see page 2) Trademark / Brand (if any) TENGEN Customer's Testing Facility (CTF) Stage used N/A aMb-800cd/efghi (a=TG, Te; b= 5, 7; c=C, L, M, H, S; d=Blank, Z, P; e=3, 3N, 4; f=3, 2; g=00, 08, 10, 20, 21, 22, 23, 30, 18, 38, Model / Type Ref. 28, 68, 67, 66, 40, 41, 42, 43, 70, 71, 72, 73, 48, 47, 46, 45, 78, 77, 76, 75; h=Blank, 2; i=A, B, C, D) Additional information (if necessary may also be See additional page(s) for further Additional information. reported on page 2) A sample of the product was tested and found IEC 60947-2:2024 to be in conformity with As shown in the Test Report Ref. No. which CN25GJSU 001 forms part of this Certificate This CB Test Certificate is issued by the National Certification Body TÜV Rheinland InterCert Kft., MEEI Division **TÜV**Rheinland[®] H-1143 Budapest, Gizella út 51-57., Hungary Web: www.tuv.com Alaran 2hag 2025 - 05 - 14Wencai Zhang Date: Signature:

Disclaimer: This is an electronically released document. The authenticity can be verified on the IECEE Website "http://certificates.iecee.org" (1.3s / 23)

Ref. Certif. No.



HU-005601

Additional information :

Interruption Medium :Air Suitability for using in IT system :Yes :40±2°C Reference temperature Breaking capacity level :C, L, M, H, S Suitability for isolation :Yes(3P and 4P) Metod of installation :Fixed, plug in Rated Ultimate Short-circuit Breaking Capacity(Icu)/ Rated Service Short-circuit Breaking Capacity(Ics) Ue:AC380/400/415V: 36kA(c=C), 50kA(c=L), 85kA(c=M), 100kA(c=H),150kA(c=S) Ue:AC500/550V : 25kA(c=C), 50kA(c=L), 50kA(c=M), 70kA(c=H), 70kA(c=S) Ue:AC660/690V : 10kA(c=C), 10kA(c=L), 20kA(c=M), 25kA(c=H), 35kA(c=S) Magnetic release Ii: AC: 5/6/7/8/9/10 In $\pm 20\%$ for power distribution, AC: 7/8/9/10/11/12 In ±20% for motor protection tripping class20;

Auxiliary and alarm contact circuits parameters : 1NO1NC, 2NO2NC, 3NO3NC, 4NO4NC; Ui:690V; Uimp:4kV; Ith:3A; AC-15: AC380V/400V/415V/0.3A; AC50/60Hz; DC-13: DC110V/220V/250V/0.15A Shunt release: Us:AC230V, AC400V; 50/60Hz; DC24V, DC110V, DC220V;Ui:690V; Uimp:4kV Undervoltage release(UVT-800): Us:AC230, AC400V; 50/60Hz; Ui:690V;Uimp:4kV Motor operating mechanism(LCD2-800):

Us:AC110V, AC230V, AC400V; 50/60Hz; DC24V, DC110V, DC220V; Ui:690V;Uimp:4kV

TÜVRheinland®

Date: 2025-05-14

Signature:

as on page 1

Page 2 of 2